

Notice of Allowability

Application No.

10/688,154

Examiner

DONNIE L. CROSLAND

Applicant(s)

CERN, YEHUDA

Art Unit

2636

-- The MAILING DATE of this communication appears on the cover sheet with the correspondence address--

All claims being allowable, PROSECUTION ON THE MERITS IS (OR REMAINS) CLOSED in this application. If not included herewith (or previously mailed), a Notice of Allowance (PTOL-85) or other appropriate communication will be mailed in due course. **THIS NOTICE OF ALLOWABILITY IS NOT A GRANT OF PATENT RIGHTS.** This application is subject to withdrawal from issue at the initiative of the Office or upon petition by the applicant. See 37 CFR 1.313 and MPEP 1308.

1. ☒ This communication is responsive to communication filed 10-17-03.
2. ☒ The allowed claim(s) is/are 1-6.
3. ☐ The drawings filed on _____ are accepted by the Examiner.
4. ☐ Acknowledgment is made of a claim for foreign priority under 35 U.S.C. § 119(a)-(d) or (f).
 - a) ☐ All b) ☐ Some* c) ☐ None of the:
 1. ☐ Certified copies of the priority documents have been received.
 2. ☐ Certified copies of the priority documents have been received in Application No. _____.
 3. ☐ Copies of the certified copies of the priority documents have been received in this national stage application from the International Bureau (PCT Rule 17.2(a)).

* Certified copies not received: _____.

Applicant has THREE MONTHS FROM THE "MAILING DATE" of this communication to file a reply complying with the requirements noted below. Failure to timely comply will result in ABANDONMENT of this application.

THIS THREE-MONTH PERIOD IS NOT EXTENDABLE.

5. ☐ A SUBSTITUTE OATH OR DECLARATION must be submitted. Note the attached EXAMINER'S AMENDMENT or NOTICE OF INFORMAL PATENT APPLICATION (PTO-152) which gives reason(s) why the oath or declaration is deficient.
6. ☒ CORRECTED DRAWINGS (as "replacement sheets") must be submitted.
 - (a) ☐ including changes required by the Notice of Draftsperson's Patent Drawing Review (PTO-948) attached
 - 1) ☐ hereto or 2) ☐ to Paper No./Mail Date _____.
 - (b) ☒ including changes required by the attached Examiner's Amendment / Comment or in the Office action of Paper No./Mail Date _____.

Identifying indicia such as the application number (see 37 CFR 1.84(c)) should be written on the drawings in the front (not the back) of each sheet. Replacement sheet(s) should be labeled as such in the header according to 37 CFR 1.121(d).
7. ☐ DEPOSIT OF and/or INFORMATION about the deposit of BIOLOGICAL MATERIAL must be submitted. Note the attached Examiner's comment regarding REQUIREMENT FOR THE DEPOSIT OF BIOLOGICAL MATERIAL.

Attachment(s)

1. ☒ Notice of References Cited (PTO-892)
2. ☐ Notice of Draftsperson's Patent Drawing Review (PTO-948)
3. ☐ Information Disclosure Statements (PTO-1449 or PTO/SB/08), Paper No./Mail Date _____
4. ☐ Examiner's Comment Regarding Requirement for Deposit of Biological Material
5. ☐ Notice of Informal Patent Application (PTO-152)
6. ☐ Interview Summary (PTO-413), Paper No./Mail Date _____
7. ☒ Examiner's Amendment/Comment
8. ☒ Examiner's Statement of Reasons for Allowance
9. ☐ Other _____


DONNIE L. CROSLAND
Primary Examiner
Art Unit: 2636

REASONS FOR ALLOWANCE

The following is an examiner's statement of reasons for allowance:

Claim 1 recites the method for configuring components for power line communications comprising installing an inductive coupler that employs a power line conductor as a primary winding; connecting a capacitor across a secondary winding of the inductive coupler for creating a resonant circuit with the secondary winding at a frequency within a desired frequency band; and connecting a communications device to the secondary winding via an impedance matching transformer, wherein the resonant circuit has a loaded Q consistent with the desired bandwidth.

Claim 2 recites a method for coupling data between a power line and a communication device comprising installing a capacitor in series with a conductive cylinder between the power line and a communication device, wherein the capacitor is for blocking power line voltage while passing a signal between the power line and the communication device, and wherein the conductive cylinder appears as a low inductance to the signal.

Claim 4 recites an arrangement of components for coupling data between a power line and a communication device comprising an inductive coupler that employs a power line conductor as a primary winding; a capacitor connected across a secondary winding of the inductive coupler for creating a resonant circuit with the secondary winding at a frequency within a desired frequency band; and an impedance matching transformer for connecting a communication device to the secondary winding, wherein the resonant circuit has a loaded Q consistent with the desired bandwidth.

Claim 5 recites an arrangement of components for coupling data between a power line and a communication device comprising a capacitor in series with a conductive cylinder between the power line and the communication device, wherein the capacitor is for blocking power line voltage while passing a signal between the power line and the communication device, and wherein the conductive cylinder appears as a low inductance to the signal.

Any comments considered necessary by applicant must be submitted no later than the payment of the issue fee and, to avoid processing delays, should preferably accompany the issue fee. Such submissions should be clearly labeled "Comments on Statement of Reasons for Allowance."

COMMENTS

Drawings


New corrected drawings are required in this application because the drawings are informal. Applicant is advised to employ the services of a competent patent draftsman outside the Office, as the U.S. Patent and Trademark Office no longer prepares new drawings. The corrected drawings are required in reply to the Office action to avoid abandonment of the application. The requirement for corrected drawings will not be held in abeyance.

In addition to Replacement Sheets containing the corrected drawing figure(s), applicant is required to submit a marked-up copy of each Replacement Sheet including annotations indicating the changes made to the previous version. The marked-up copy must be clearly labeled as "Annotated Marked-up Drawings" and must be presented in the amendment or remarks section that explains the change(s) to the drawings. See 37 CFR 1.121(d).

Any inquiry concerning this communication or earlier communications from the examiner should be directed to DONNIE L. CROSLAND whose telephone number is (703) 305-4388. The examiner can normally be reached on Mon-Fri, 9:30a-6:00p.

If attempts to reach the examiner by telephone are unsuccessful, the examiner's supervisor, JEFFERY HOFSSASS can be reached on (703) 305-4717. The fax phone number for the organization where this application or proceeding is assigned is 703-872-9306.

Information regarding the status of an application may be obtained from the Patent Application Information Retrieval (PAIR) system. Status information for published applications may be obtained from either Private PAIR or Public PAIR. Status information for unpublished applications is available through Private PAIR only. For more information about the PAIR system, see <http://pair-direct.uspto.gov>. Should you have questions on access to the Private PAIR system, contact the Electronic Business Center (EBC) at 866-217-9197 (toll-free).



DONNIE L. CROSLAND
Primary Examiner
Art Unit 2636

Dlc
9-16-04